



Approved Meter Bases

Single Phase Meter Bases

	100 AMP OH/UG	200 AMP OH	200 AMP UG	200 AMP OH/UG	200 AMP w/disconnect OH/UG	320 AMP OH/UG
Milbank	U7487-RL-TG	U7021-RL-TG-BL	U1980-O-BL	U7043-XL-TG-BL	U5168-XTL-200	U4433X-BL or U1797-O-K3L-K2L-BL
Durham	UT-RS101B	UT-RS202B	UT-RS223A			1006464
Eaton	UTRS101BE	UTRS202BCH	UTRS223ACH	UTRS213CE		UTH4330T-CH*
Square D	UTRS101BE-SQD	UTRS202B-SQD	UTRS223A-SQD			UTH4330T-SQD*
Midwest	UTRS101BE-MEP	UTRS202B-MEP	UAS877-PG		R281CB1LK	UTH4330T-MEP*

* Requires U04 Closing Plate

Three Phase Self Contained Meter Bases

	200 Amp OH/UG	320 AMP OH/UG
Milbank	U9701-RRRL-BL	U2594-X
Durham	UT-H7213B	UT-H7330U
Eaton	CH	
Square D	SQD	SQD
Midwest	MEP	MEP

Requirements

- 1) UL Approved with label (Underwriters Laboratories)
- 2) Ringless steel construction (galvanized and painted gray)
- 3) All Network, Multi Position, and Gang bases must have pre-approval from Engineering Department.
- 4) Non-approved meter bases will not be energized by CEMC.
- 5) All UG bases require 3" slip coupling

4/9/2020